



- FLAG NOTES**
- ① DEDICATED 120VAC FOR FACU POWER CONNECTION.
 - ② WEATHERPROOF BELL FOR SPRINKLER NOTIFICATION.
 - ③ ADDRESSABLE RELAY FOR FAN COIL UNIT SHUTDOWN.
 - ④ ADDRESSABLE RELAY FOR ACCESS CONTROL.
 - ⑤ ADDRESSABLE MODULE FOR RESCUE ASSISTANCE SYSTEM MONITORING.
 - ⑥ ADDRESSABLE RELAY FOR SOUND MASKING SYSTEM SHUTDOWN.

WIRE CHART

| SYMBOL | CIRCUIT TYPE | GAUGE | CONSTRUCTION | TYPE |
|--------|--------------------------|--------|-------------------|-----------|
| M | IDNET | 18 AWG | UTP SOLID | FPLR FPLP |
| A | ADDRESSABLE NOTIFICATION | 14 AWG | UTP SOLID | FPLR FPLP |
| C | RUI + COMMUNICATION | 18 AWG | UTP SOLID | FPLR FPLP |
| D | REMOTE TEST SWITCH/LED | 14 AWG | (2) 2 COND. SOLID | FPLR FPLP |
| S | AUDIO - SPEAKER | 18 AWG | UTP SOLID | FPLR FPLP |
| H | POWER | 14 AWG | 2 COND. SOLID | FPLR FPLP |
| I | RELAY | 14 AWG | 2 COND. SOLID | FPLR FPLP |
| K | VISUAL | 14 AWG | 2 COND. SOLID | FPLR FPLP |
| L | ZONE CIRCUIT | 14 AWG | 2 COND. SOLID | FPLR FPLP |

ISSUE LOG

| ISSUE # | DATE | DESCRIPTION |
|---------|------|-------------|
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |
| - | - | - |

DRAWN BY: DATE: JOB OR CASE # SALESFORCE CASE

DEVICE PLACEMENT - CONDUIT

FAS-101

