



- FLAG NOTES**
- ⊙ DEDICATED 120VAC FOR FACU POWER CONNECTION.
 - ⊙ WEATHERPROOF BELL FOR SPRINKLER NOTIFICATION.
 - ⊙ ADDRESSABLE RELAY FOR FAN COIL UNIT SHUTDOWN.
 - ⊙ ADDRESSABLE RELAY FOR ACCESS CONTROL.
 - ⊙ ADDRESSABLE MODULE FOR RESCUE ASSISTANCE SYSTEM MONITORING.
 - ⊙ ADDRESSABLE RELAY FOR SOUND MASKING SYSTEM SHUTDOWN.

WIRE CHART

SYMBOL	CIRCUIT TYPE	GAUGE	CONSTRUCTION	TYPE
M	IDNET	18 AWG	UTP SOLID	FPLR FPLP
A	ADDRESSABLE NOTIFICATION	14 AWG	UTP SOLID	FPLR FPLP
C	RUI + COMMUNICATION	18 AWG	UTP SOLID	FPLR FPLP
D	REMOTE TEST SWITCH/LED	14 AWG	(2) 2 COND. SOLID	FPLR FPLP
S	AUDIO - SPEAKER	18 AWG	UTP SOLID	FPLR FPLP
H	POWER	14 AWG	2 COND. SOLID	FPLR FPLP
I	RELAY	14 AWG	2 COND. SOLID	FPLR FPLP
K	VISUAL	14 AWG	2 COND. SOLID	FPLR FPLP
L	ZONE CIRCUIT	14 AWG	2 COND. SOLID	FPLR FPLP

ISSUE LOG

ISSUE #	DATE	DESCRIPTION
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

DRAWN BY: DATE: JOB OR CASE #

DRAWN BY: DATE: SALESFORCE CASE #



SCALE: 1/8" = 1'-0" IN FEET

0 4 8 16

DEVICE PLACEMENT - WIRING

FAS-100