




# ADDRESSABLE SIGNAL IAM

AUTOCALL A4090-9007



MOUNTING OPTION "A"



## WIRING NOTES

1. SEE TERMINAL MAP BELOW FOR PROPER CONNECTIONS.
2. MAINTAIN CORRECT POLARITY ON TERMINAL CONNECTIONS.
3. ALWAYS CUT CONDUCTORS AND SECURE UNDER TERMINALS. NEVER LOOP WIRES UNDER TERMINALS.
4. ANY WIRE SPLICES TO BE MADE BY LISTED AND AHJ APPROVED METHODS (CLASS B ONLY).

## MOUNTING OPTIONS

OPTION <sup>1</sup>	DESCRIPTION	NOTE
A	4" (102mm) SQUARE BOX, 2-1/8" MINIMUM DEPTH WITH DOUBLE GANG COVER PLATE.	BY OTHERS
B	4" (102mm) SQUARE BOX, 2-1/8" MINIMUM DEPTH WITH AUTOCALL A4090-9801 TRIM PLATE FOR SEMI-FLUSH MOUNTED BOX	BOX BY OTHERS, PLATES ORDERED SEPARATELY
C	4" (102mm) SQUARE BOX, 2-1/8" MINIMUM DEPTH WITH AUTOCALL A4090-9802 TRIM PLATE FOR SURFACE MOUNTED BOX	BOX BY OTHERS, PLATES ORDERED SEPARATELY

1. FOR ADDITIONAL MOUNTING OPTIONS, DOWNLOAD DATA SHEET A4090-0010 FROM [HTTP://WWW.AUTOCALL.COM](http://www.autocall.com)

TERMINAL MAP	
1	ADDRESSABLE LOOP +
2	ADDRESSABLE LOOP -
3	ADDRESSABLE LOOP SHIELD
4	SIGNAL IN +
5	SIGNAL IN -
6	SIGNAL IN SHIELD
7	SIGNAL RETURN -
8	SIGNAL RETURN +
9	SIGNAL OUT -
10	SIGNAL OUT +
11	SHIELD



Owner

Project Name

No.	Description	Date
01	For Review	07/14/2021

Autocall Modules  
A4090-9007

Project number		01
Date	07/12/2021	
Drawn by	CV	
Checked by	MA	Scale NTS