

CONNECT TO  
120VAC 60HZ

**PANEL\_A008**


PANEL\_LOCATION\_1  
PANEL\_LOCATION\_2

SCALE: NTS

PANEL DETAIL

**A008 TERMINATIONS**

TERMINATION NUMBER		
CIRCUIT LABEL	CKT DESCRIPTION	WIRE
1	IDC8 TO IDC DEVICES	Z
2	IDC7 TO IDC DEVICES	Z
3	IDC6 TO IDC DEVICES	Z
4	IDC5 TO IDC DEVICES	Z
5	IDC4 TO IDC DEVICES	Z
6	IDC3 TO IDC DEVICES	Z
7	IDC2 TO IDC DEVICES	Z
8	IDC1 TO IDC DEVICES	Z
9	NAC1 TO NAC DEVICES	V
10	NAC2 TO NAC DEVICES	V
11	RLY4 COMMON TROUBLE RELAY	R
12	RLY3 SUPERVISORY RELAY	R
13	RLY2 ALARM RELAY	R
14	RLY1 TROUBLE RELAY	R
15	AUX2 24 VDC TO CONVENTIONAL DETECTORS	P
16	AUX1 24 VDC TO REMOTE ANNUNCIATOR	P
17	RS485 RS485 TO REMOTE ANNUNCIATOR	B



ISSUE LOG:

MARK#	DATE	DESCRIPTION
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

DRAWN BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
JOB OR CASE # \_\_\_\_\_ SALESPERSON CASE \_\_\_\_\_

PANEL DETAIL

FAS-401