



A050 TERMINATIONS

TERMINATION NUMBER			
CIRCUIT LABEL	CKT DESCRIPTION		WIRE
1	NAC 1	TO NAC DEVICES	V
2	NAC 2	TO NAC DEVICES	V
3	MX	TO MX DEVICES	M
4	RLY1	TROUBLE RELAY	R
5	RLY2	ALARM RELAY	R
6	RLY3	SUPERVISORY RELAY	R
7	RS485	RS485 TO REMOTE ANNUNCIATOR	B
8	AUX1	24 VDC TO REMOTE ANNUNCIATOR	P
9	AUX2	24 VDC TO CONVENTIONAL DETECTORS	P

CONNECT TO  
120VAC 60HZ

PANEL\_A050  
PANEL\_LOCATION\_1  
PANEL\_LOCATION\_2

SCALE: NTS

CUSTOMER'S NAME  
CUSTOMER'S ADDRESS  
CUSTOMER'S CITY STATE ZIP CODE

AUTHORIZED DEALER'S NAME  
AUTHORIZED DEALER'S ADDRESS  
AUTHORIZED DEALER'S CITY STATE ZIP CODE  
AUTHORIZED DEALER'S PHONE NUMBER  
AUTHORIZED DEALER'S EMAIL ADDRESS

ISSUE LOG:		
MARK	DATE	DESCRIPTION
MARK#1	DATE#1	DESCRIPTION#1
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

DRAWN BY: DATE: JOB OR CASE #:	DRAWN BY: DATE: SALESFORCE CASE:
--------------------------------------	--