



**A007 TERMINATIONS**

TERMINATION NUMBER	CIRCUIT LABEL	CKT DESCRIPTION	WIRE
1	NAC 1	TO NAC DEVICES	V
2	NAC 2	TO NAC DEVICES	V
3	NAC 3	TO NAC DEVICES	V
4	NAC 4	TO NAC DEVICES	V
5	MX	TO MX DEVICES	M
6	RLY1	TROUBLE RELAY	R
7	RLY2	ALARM RELAY	R
8	RLY3	SUPERVISORY RELAY	R
9	RS485	RS485 TO REMOTE ANNUNCIATOR	B
10	AUX1	24 VDC TO REMOTE ANNUNCIATOR	P
11	AUX2	24 VDC TO CONVENTIONAL DETECTORS	P

CONNECT TO  
120VAC 60HZ

**PANEL\_A250**

PANEL\_LOCATION\_1  
PANEL\_LOCATION\_2

SCALE: NTS

ISSUE LOG:

MARK#	DATE#	DESCRIPTION
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-